

# hagergroup

Hager LTD  
Hortonwood 50  
TELFORD  
TF1 7FT  
UK

## MANUFACTURER'S DECLARATION:

BS 7671:2018 Amendment 2 : 2022, regulation 551.7.2 (v) requires that

Where the generating set may operate in parallel with the supply for distribution of electricity to the public and is connected via a low voltage switchgear and controlgear assembly. The assembly shall be selected such that:

$$I_{nA} \geq I_n + I_{g(s)}$$

Where:

$I_{nA}$  is the rated current of the assembly

$I_n$  is the rated current or current setting of the incoming circuit overcurrent protective device either incorporated within the low voltage switchgear and controlgear assembly or upstream of it


$I_{g(s)}$  is the rated output current of the generating set or sets.

Hager main switch controlled consumer units have been tested and verified with  $I_{nA} = 116$  A to meet the requirements of G98 for parallel generator installations under the following installation conditions


- i) The input from the generator must be electrically farthest from the main switch.
- ii) The protective device shall have a 0.8 Rated Diversity Factor (RDF) applied i.e. be a rated current of 20 A.
- iii) The protective device can be either MCB or RCBO (where installation conditions require an RCBO due to the need for additional protection).  
The RCBO shall be:-
  - DP i.e. switch all live conductors including the neutral &
  - Bidirectional which can be determined by the absence of directional marking on the terminals.
  - Selected in accordance with the inverter manufacturer's instructions.




$$I_{nA} \geq I_n + I_{g(s)}$$
$$100 \text{ A} + 16 \text{ A} = 116 \text{ A}$$



551.7.2 (v)



$$I_{nA} \geq I_n + I_{g(s)}$$
$$100 \text{ A} + 16 \text{ A} = 116 \text{ A}$$



551.7.2 (v)